

CERTIFICATE OF COMPLIANCE

Certificate Number 20190923-EX28188
Report Reference EX28188-20190917
Issue Date 2019-SEPTEMBER-23

Issued to: DUYAR VANA MAKINA SAN VE TIC A S
Osmangazi Mh. 2653 Sk. No:7
34522 Esenyurt Istanbul TURKEY

**This certificate confirms that
representative samples of**

BUTTERFLY VALVES
SEE ADDENDUM PAGE

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 1091 Standard for Butterfly Valves for Fire-Protection
Service
UL 312 Standard For Check Valves for Fire-Protection
Service


Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




CERTIFICATE OF COMPLIANCE

Certificate Number 20190923-EX28188
Report Reference EX28188-20190917
Issue Date 2019-SEPTEMBER-23

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Nominal Pipe Size, NPS	Rated Pressure, psig	End Configuration	Indicator Post	Supervisory Switch
Y-4020	2-1/2, 3, 4, 5, 6 and 8	300	Wafer	-	-



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

